

# DRAFT DETERMINATION – PARTICIPANT RESPONSE PACK

## METER CHURN PACKAGE

***Participant:*** Ausgrid (TCAUSTM)

***Completion Date:*** 8<sup>th</sup> December 2014

# Table of Contents

<b>1. PROPOSED CHANGES</b> .....	<b>3</b>
A. PROPOSED CHANGES TO THE METER CHURN PACKAGE .....	3

# 1. Proposed Changes

- Meter Churn procedure for Financially Responsible Market Participants (New Document)
- SLP Metering Data Provider Services – Section 8 and Section 9
- SLP Metering Provider Services Category B for Metering Installation Types 1, 2, 3, 4, 5 and 6

**NOTE:** Below are two specific things requiring comment:

Effective date of implementation

Significant change to 8.1.6 (c) of the MDP SLP.

Other minor changes please refer to the combined response packs for more information.

Please include your comments in the 'Participant Comment' column below.

## A. Proposed Changes to the Meter Churn Package

Item	Description	Category	Participant Comments
<b>1</b>	<b>PROPOSED/ REQUESTED CHANGES</b>		
1.1	<p>During the feedback process for first stage consultation AEMO received comments regarding the implementation date of December 2014. Feedback received requested a September or November 2015 implementation date.</p> <p>Implementation dates were discussed at the MSWG on the 31st October 2014 with the most favourable date being November 2015 by the members of the MSWG.</p> <p>AEMO has provided 2 options:</p> <p>Implementation date of 30th September 2015 as per majority of the feedback from participants;</p> <p>Or</p> <p>Implementation date of November 2015 to align with a MSATS/B2B system release.</p>	<b>Procedure Only</b>	Ausgrid would agree that a November 2015 implementation date aligning with the MSATS/B2B system release would be most appropriate.
<b>MDP Service Level Procedure</b>			
1.2	<p>Section 8</p> <p>8.1.6 (c) change to the clause</p> <p>(c) Where the <i>Metering Data Provider</i> is changing as a result of the <i>Meter Churn</i> and there is a delay in the change of the <i>Metering Data Provider</i> role in</p>	<b>Procedure Only</b>	<p>Ausgrid suggests that the MDP should be able to adopt either process:-</p> <p>i. To deactivate the data</p>

Item	Description	Category	Participant Comments
	<p>MSATS:</p> <p>i. the <i>Metering Data Provider</i> must make the data stream inactive in MSATS for the removed meter with an effective start date of the <i>Meter Churn</i> day.</p> <p><del>i. the old Metering Data Provider must provide substituted metering data in accordance with the metrology procedure: Part B with a quality flag of 'S' and a reason code of 37 (meter under churn) in the MDFF until the new Metering Data Provider becomes the Metering Data Provider in MSATS; and</del></p> <p><del>ii. the new Metering Data Provider, when it becomes the Metering Data Provider in MSATS, must provide actual metering data for the period of substitution in (c)(i) above.</del></p>		<p>streams in accordance with the proposed change; OR</p> <p>i. Leave the data streams active and provide substituted data to AEMO and market participants until the transfer of service provider(s) is complete.</p> <p>Where the NMI(s) concerned have very high consumption (or generation), the exclusion of any data for such NMIs from the market could have an adverse impact on settlements. For example, if the subject NMI(s) were classified as wholesale and the meters were exchanged on a Friday, both Friday's and Saturday's data would be excluded from settlements.</p> <p>If AEMO elects to adopt only one process, then option (ii) is the only acceptable approach.</p>
1.3	<p>Section 6 6.11.5</p> <p>The <i>Metering Data Provider</i> must provide <i>metering data</i> to the <i>financially responsible Market Participant</i> within two <i>business days</i> of receiving a completed notification of a change of <i>financially responsible Market Participant</i>, including <i>estimated metering data</i>, for a type 5, 6 or 7 <i>metering installation</i>.</p>	<b>Procedure Only</b>	Data delivery requirements should include delivery of data to AEMO and LNSPs.
1.4	<p>Section 6 8.1.6 (b) (i)</p>	<b>Procedure Only</b>	This is a duplicate of clause 8.1.6 (a) (iv). Suggest deletion of clause 8.1.6 (a) (iv).

Item	Description	Category	Participant Comments
	for the removal of type 1, 2, 3, or 4 <i>metering equipment</i> , the old <i>Metering Data Provider</i> must provide the new <i>Metering Data Provider</i> with the final metering data from the removed <i>metering equipment</i> in accordance with section 6 of this Procedure;		
1.5	Section 6 8.6.1 (c)	Procedure Only	Refer to comments (above)
<b>MP Service Level Procedure</b>			
1.6	Section 4 4.11.1 Comment	Procedure Only	Meter Churn can be initiated without a request from the RP or FRMP. For example, as a result of a meter failure or fault. The SLP needs to allow the MP to initiate meter churn for any reason associated with emergency or routine meter rollouts.
<b>Meter Churn Procedure for FRMPs</b>			
1.7	No Comments	Procedure Only	